



Orange Water and Sewer Authority

Our community's trusted partner for clean water and environmental protection

ADDENDA

ADDENDUM NUMBER 01

DATE: 9-12-2024

PROJECT: Off-Site Biosolids Tank #2 Cleanout and Condition Assessment

OWASA CIP NUMBER: 378-07

OWNER: ORANGE WATER AND SEWER AUTHORITY

TO: ALL SUBMITTERS

This Addendum is to provide answers to questions submitted by Consulting Firms concerning this RFQ.

Addenda #01 consists of 1 page:

Questions:

1. What is the estimated level of sludge in the tank?

A: The sludge level is estimated to be 10 feet from the floor of the tank

2. Is water from nearby Collins Creek available for use?

A: No, while Collins Creek could provide a small amount of water, any major water usage would require bringing in water tanks.

3. Does OWASA need to continue access to site during project?

A: Yes, OWASA requires access to site. Tankers do not access the site often and are flexible with regards to operation but will need to access site.

Addenda

Off-Site Biosolids Tank #2 Cleanout and Condition Assessment



Orange Water & Sewer Authority