



Orange Water and Sewer Authority

Our community's trusted partner for clean water and environmental protection

ADDENDA

ADDENDUM NUMBER 02

DATE: 9-13-2024

PROJECT: Cane Creek Raw Water Pump Station Electrical Improvements

OWASA CIP NUMBER: 270-16

OWNER: ORANGE WATER AND SEWER AUTHORITY

TO: ALL SUBMITTERS

This Addendum is to provide answers to questions submitted by Consulting Firms concerning this RFQ.

Addenda #02 consists of 1 page:

Questions:

1. Is project area located within 100-year flood plain?

A: No, the project area is not located within the 100-year flood plain.

2. Are there any additional scope of work items OWASA is considering?

A: Yes, OWASA is considering the addition of a condition assessment for the raw water pumps to the scope of work.

3. Do all electrical upgrades need to be installed within the existing electrical room?

A: No, all upgrades do not have to be installed within the existing electrical room. Because Cane Creek is the primary source of water for Jones Ferry Water Treatment Plant, OWASA is prioritizing MOPO and minimization of equipment down time.

Addenda

Cane Creek Raw Water Pump Station Electrical Improvements



Orange Water & Sewer Authority